

TLP03 CL										
Потолок	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Стены	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Рабочая плоскость	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
k = 0.60	52	44	39	51	43	39	50	43	39	34
0.80	59	51	47	59	51	46	57	51	46	41
1.00	65	58	53	64	58	53	63	58	52	48
1.25	70	63	59	69	63	58	67	62	58	53
1.5	74	67	63	73	67	62	70	65	61	56
2.00	78	73	68	77	72	68	74	70	67	61
2.5	81	76	72	79	74	71	76	72	69	63
3.00	83	78	75	81	77	74	78	75	72	66
4.00	85	82	78	84	80	77	80	78	75	69
5.00	87	84	81	85	82	80	82	79	77	70

TLP03 OL										
Потолок	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Стены	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Рабочая плоскость	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
k = 0.60	48	39	33	47	38	33	46	38	33	28
0.80	56	47	41	55	46	41	53	46	41	35
1.00	62	54	48	61	53	48	59	54	47	42
1.25	68	60	54	67	59	54	64	58	53	48
1.5	72	64	59	70	63	58	68	62	58	52
2.00	77	70	65	75	69	65	73	68	64	58
2.5	80	74	69	78	73	69	75	71	67	61
3.00	82	77	73	81	76	72	77	74	70	64
4.00	85	81	78	83	80	76	80	77	74	67
5.00	87	84	80	85	82	79	82	79	77	70

TLP03 CLM										
Потолок	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Стены	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Рабочая плоскость	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
k = 0.60	39	33	29	39	33	29	38	32	29	25
0.80	46	39	35	45	39	35	44	38	35	31
1.00	51	45	40	50	44	40	49	45	40	36
1.25	55	49	45	54	49	45	53	48	44	40
1.5	58	52	49	57	52	48	55	51	48	43
2.00	62	57	53	61	56	53	59	55	52	48
2.5	64	59	56	63	59	56	60	57	54	50
3.00	66	62	59	64	61	58	62	59	57	52
4.00	68	65	62	66	64	61	64	61	60	54
5.00	69	66	64	68	65	63	65	63	61	56